

Verification / Inspection report submitted by the Security and Fire Safety Officer, SVIMS on Fire Extinguisher points at SVIMS as on date 20th October-2016

FIRE EXTINGUISHERS (SVIMS MAIN BUILDING)

NOMENCLATURE	REMARKS
DCP 5 kg./6 kg. – 51	All fire extinguishers are in working condition, its due date for refilling is December-2016 Except CO2 4.5kg.-03, DCP(5kg.)-02 and DCB(02 kg.)-06 nos. were used for training purpose and to be sent for refilling purpose.
DCP 2 Kg. – 12	
DCP (ABC) 2kg. - 20	
CO2 (4.5kg.) - 47	
Total: 191	

All corrected Y/N Y

FIRE EXTINGUISHERS (SPMCW)

NOMENCLATURE	REMARKS
DCP 5 kg./6 kg. – 79	All fire extinguishers are in working condition, its due date for refilling is August-2017
CO2 (4.5kg.) - 54	
Total: 133	

All corrected Y/N Y

FIRE EXTINGUISHERS (IPW)

NOMENCLATURE	REMARKS
DCP 5 kg./6 kg. – 08	All fire extinguishers are in working condition, its due date for refilling is June-2017
CO2 (4.5kg.) - 07	
Water Type-(09 ltrs.) - 11	
Total: - 26	

All corrected Y/N Y

Total Fire Extinguishers in SVIMS – 350 nos.

Sd/- Fire Safety Officer / Security Officer

Reviewed and Sd/- Director cum Vice Chancellor,
SVIMS, Tirupati