Verification / Inspection report submitted by the Fire Safety Officer, SVIMS Fire Extinguisher, Fire Hydrant system at SVIMS SPMC(W) Hospital & College

FIRE EXTINGUISHERS, HYDRANT SYSTEM AUTOMATIC DETECTION AND ALARM SYSTEM (SVIMS MAIN BUILDING)

NOMENCLATURE		REMARKS
Fire Extinguishers	191 Nos.	
Internal Hose Cabinet (15 mtrs x 2) RRL Hoses &Branch Pipes	104 Nos.	
Yard Cabinet with Branch pipe Hoses	48 Nos.	
30 Mtrs First AID Hose Reel Drum	128 Nos.	All fire extinguishers & Hydrant
Manual Call Point	32 Nos.	system equipments are in working condition,
Smoke Detectors	156 Nos.	
Wet Risers	59 Nos.	
Sprinklers	73 Nos.	
Main electric pump with Motor	02 Nos.	
Jacky Pump with Motor	02 Nos.	
Diesel Pump	02 Nos.	
Control Panel Box	02 Nos.	

All corrected Y/N

Υ

FIRE EXTINGUISHERS, HYDRANT SYSTEM AUTOMATIC DETECTION AND ALARM SYSTEM SPMC(W) HOSPITAL

NOMENCLATURE		REMARKS
Fire Extinguishers	502Nos.	
Hose Reel Systems	53 Nos.	
Wet Riser (each floor)	10 Nos	
Yard Hydrants	45 Nos.	
Automatic Sprinkler System	4157 Nos.	All fire extinguishers &
Manually Operated Electric Fire alarm system	14 Nos.	Hydrant system equipments are in working
Automatic Detection & Alarm system	890 Nos.	condition,
Underground tank	200000 Ltrs.	
Terrace Tank	20000 Ltrs.	
Fire pump	0.45	

All corrected Y/N

Υ

FIRE EXTINGUISHERS, HYDRANT SYSTEM, AUTOMATIC DETECTION AND ALARM SYSTEM SPMC(W) COLLEGE

NOMENCLATURE		REMARKS
Fire Extinguishers (CO2 type)	75 Nos.	
Fire Extinguishers (ABC type)	100 Nos.	
S&F Hose Cabinet	20 Nos.	
Sprinklers pendent	80 Nos.	
Photo Electric Detector	1002 Nos.	
Manual call points	51 Nos.	All fire extinguishers & Hydrant system equipments
Strobe cum Hooters	51 No.	are in working condition
14 Zone Fire control Panel	04 Nos.	
Repeater panel	04 Nos.	
Booster pump	01 Nos.	
2HP Submersible Motor pump set	01 Nos.	
GM Hydrant valve	20 Nos.	

All corrected Y/N

Υ

Sd/- Fire Safety Officer

Reviewed and Sd/- Director cum Vice

Chancellor, SVIMS, Tirupati